



Underwriters Laboratories Inc.®

Northbrook, Illinois • (847) 272-8800

Melville, New York • (516) 271-6200

Santa Clara, California • (408) 985-2400

Research Triangle Park,  
North Carolina • (919) 549-1400

Camas, Washington • (360) 817-5500

## CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 030698 - EX4267  
ISSUE DATE: June 3, 1998

Issued to: Wouter Witzel B V  
Postbus 465  
7500 Al Enschede, NETHERLANDS

Report Reference: EX4267, February 22, 1991

This is to Certify that representative samples of: Butterfly Valves, Models EVS, EVBS and EVTLS

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1091, Butterfly Valves for Fire Protection Service.


Additional Information: *The Model EVS butterfly valves are of the wafer type. Models EVBS and EVTLS valves are of the lug type. These valves are intended for use as water supply control valves for fire protection. They are also intended for aboveground installation. Maximum rated working pressure and the direction of intended flow are marked on each valve. Valve Sizes: 65, 80, 100, 125, 150, 200 and 300 mm (2-1/2, 3, 4, 5, 6, 8, 10 and 12 in.). These valves are designed for working pressures not exceeding 175 psi. Installation instructions are provided with each valve.*

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" (UL); the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer:   
Underwriters Laboratories Inc.  
Nikola Momcilovic

Review Engineer:   
Underwriters Laboratories Inc.  
A. M. Ramirez