

FEDERAL AUTHORITY ON SUPERVISION  
OF CONSUMER RIGHTS AND HUMAN WELL-BEING

ADMINISTRATION OF FEDERAL AUTHORITY ON SUPERVISION  
OF CONSUMER RIGHTS AND HUMAN WELL-BEING OF MOSCOW

**SANITARY-EPIDEMIOLOGICAL CONCLUSION**

№ 77 . 01 . 16 . 495 . П . 064052 . 09 . 09 dated 22 . 09 . 2009

Current sanitary-epidemiological conclusion states that production of:  
**Stainless steel, steel alloy, aluminum bronze pipeline armature of trading mark "Wouter Witzel EuroValve": butterfly valves with rubber sealing, types EV, EVF, EVS, EVL, EVCS, EVBS, EVBLS, EVBTLs, EVUS, EVML, EVMS, EVFS, EVFL, ECV**

Manufactured in accordance with  
**Quality declaration**

MEETS THE REQUIREMENTS of sanitary-epidemiological rules:  
**ГН 2.1.5.1315-03 "Maximum admissible concentration of chemical substances in water of water objects of household-drinking and cultural-domestic water use. Hygiene specifications"; ГН 2.1.5.2307-07.**

Organization-manufacturer  
**"Wouter Witzel EuroValve BV"**  
**Address: 7581 CZ Losser, P.O. Box 54 / 7580 AB Losser, Netherlands**

Receiver of Sanitary-epidemiological conclusion  
**"Wouter Witzel EuroValve BV"**  
**Address: 7581 CZ Losser, P.O. Box 54 / 7580 AB Losser, Netherlands**

The basis for production approval, that meets the requirements of sanitary rules, are:  
**Tests protocol № 499-0376 dated 21 september 2009 "IZ Sergievo- Posadskogo filial FGU "Mendeleevskiy ZSM"", accreditation certificate GSEN № POCC RU.0001.516503. Expert conclusion № 65422 dated 22 september 2009. FGUZ "Moscow center for hygiene and epidemiology" .**

**№ 2513525**

# HYGIENIC CHARACTERISTICS OF PRODUCTION

Substances Indicators (Factors)	Hygienic Specifications (SanPiN, MDU, PDK and others.)
Iron, mg/dm <sup>3</sup>	0,3
Manganese, mg/dm <sup>3</sup>	0,1
Nickel, mg/dm <sup>3</sup>	0,1
Chrome, mg/dm <sup>3</sup>	0,1
Acrylonitrile	0,03
Toluene	0,6
Benzene	0,1
Xylene	0,2
TMTD	0,02
Dimethyl dicarbonate zinc	0,6
Dimethylamine	0,0025
Hexamethylenediamine	,001
Zinc	1,0

Field of application

**in systems of household-drinking water supply**

Conditions necessary for using, storage, transportation and security measures:

**In accordance with recommendations of manufacturer**

Information placed on the label:

**Name of the product, country, manufacturer, purpose, composition, manual in Russian.**

Conclusion valid till **22.09.2014**

Main state health officer  
(Deputy main state health officer)



\_\_\_\_\_  
Signature

**Filatov N.N.**